

**COUNTY OF HUDSON**

**NOTICE TO BIDDERS**

**ADDENDUM**  
**TO BID NO. 6449**

Notice is hereby given that Bid No. 6449 INSPECTION, TESTING, ROUTINE MAINTENANCE AND REPAIR OF FIRE SPRINKLER, STANDPIPE, PUMP, HYDRANT AND SUPPRESSION SYSTEMS AT VARIOUS HUDSON COUNTY FACILITIES was postponed on February 2, 2010. The rescheduled date is now MARCH 23, 2010.

Please be advised that the BID CORRECTIONS AND CLARIFICATIONS are available by calling our office at (201) 795-6280. Thank you!

*By: Deborah Gallagher*  
*Purchasing Agent*

*For: Wade Frazee, Director,*  
*Dept. of Finance & Administration*

Adv. 3/9/2010

COUNTY OF HUDSON  
DEPARTMENT OF FINANCE AND ADMINISTRATION  
DIVISION OF PURCHASING

Administration Annex  
567 Pavonia Avenue  
Jersey City, NJ 07306

Phone: (201) 795-6280  
Fax: (201) 369-4361



THOMAS A. DE GISE  
County Executive

WADE FRAZEE  
Director

DEBORAH GALLAGHER  
Purchasing Agent

March 4, 2010

Via Facsimile Transmission  
SIMPLEXGRINNELL  
200 FORGE WAY  
ROCKAWAY, NJ 07866

Attn: DICK PEKARIK

Fax: (973)-586-4413


Re: **Bid No.6449 INSPECTION, TESTING, ROUTINE MAINTENANCE AND REPAIR OF FIRE SPRINKLER, STANDPIPE, PUMP, HYDRANT AND SUPPRESSION SYSTEMS AT VARIOUS HUDSON COUNTY FACILITIES**

Dear Mr. PEKARIK:

Please find this letter in response to your fax inquiry of JANUARY 28,210

1. **Question #1** -The bid asks for semiannual testing of sprinkler systems-Is this correct?  
**Answer:** The bid is amended to require **quarterly** testing of the fire sprinkler systems.
2. **Question #2** - Are you requiring a foam concentrate analysis of the foam system?  
**Answer:** **NO.**
3. **Question #3** - Are there twenty-four (24) preaction systems included in the bid scope?  
**Answer:** The bid is amended to **include twenty-four (24) preaction systems.**
4. **Question #4** - Do the fire pumps require only annual testing?  
**Answer:** The bid is amended to require **only annual testing.**

Sincerely,

  
Deborah Gallagher  
Purchasing Agent

DG:lm  
Encls.

cc: To All Prospective Bidders

**SimplexGrinnell** BE SAFE.

A Tyco International Company

200 Forge Way  
Rockaway, NJ 07066  
P. 973.586.8844  
F. 973.586.4413

January 28, 2010

Debra Gallagher  
Purchasing Agent  
County of Hudson  
State of New Jersey  
567 Pavonia Avenue  
Jersey City, NJ

Re: Bid No. 6449 Inspection, Testing, Routine Maintenance and Repair of Fire Sprinkler, Standpipe, Pump, Hydrant and Suppression Systems at Various Hudson County Facilities

Dear Miss Gallagher:

The bid scope work indicates that you are only asking for semiannual testing of the Fire Sprinkler System. NFPA25 and State codes require quarterly testing of Wet, Dry and Preaction sprinkler system. Was this an oversight?


In reference to the Hudson County Plaza, you show a foam system. Are you requiring a foam concentrate analysis?

In reference to the Hudson County Correctional Facility, based on previous experience with this facility, there are 24 preaction systems that are not shown on the bid scope. Is this an oversight?

Fire pumps are also included in this bid. The NFPA25 and State Code require only annual testing for Fire pumps. Was this an oversight?

Please advise as soon as possible so that I can prepare my bid package.

You can reach me by fax at 973 586-4413. Sincerely,



Dick Pekarik  
Service Sales Rep